

Retraction

Retracted: Contamination of Hospital Water Supplies in Gilan, Iran, with *Legionella pneumophila*, *Escherichia coli*, and *Pseudomonas aeruginosa*

Interdisciplinary Perspectives on Infectious Diseases

Received 29 September 2016; Accepted 29 September 2016

Copyright © 2016 Interdisciplinary Perspectives on Infectious Diseases. This is an open access article distributed under the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

Interdisciplinary Perspectives on Infectious Diseases has retracted the article titled “Contamination of Hospital Water Supplies in Gilan, Iran, with *Legionella pneumophila*, *Escherichia coli*, and *Pseudomonas aeruginosa*” [1]. The article was found to contain a substantial amount of material, without citation, from previously published articles.

References

- [1] M. Ahmadi Jalali Moghadam, H. Honarmand, and S. Asfaram Meshginshahr, “Contamination of hospital water supplies in Gilan, Iran, with *Legionella pneumophila*, *Escherichia coli*, and *Pseudomonas aeruginosa*,” *Interdisciplinary Perspectives on Infectious Diseases*, vol. 2015, Article ID 809842, 7 pages, 2015.

Research Article

Contamination of Hospital Water Supplies in Gilan, Iran, with *Legionella pneumophila*, *Escherichia coli*, and *Pseudomonas aeruginosa*

Masoumeh Ahmadi Jalali Moghadam,¹ Hamidreza Honarmand,²
and Sajad Asfaram Meshginshahr³

¹Cellular and Molecular Research Center, Guilan University of Medical Sciences, Rasht, Iran

²Department of Microbiology, Guilan University of Medical Sciences, Rasht, Iran

³Department of Microbiology, Islamic Azad University, Lahijan Branch, Lahijan, Iran

Correspondence should be addressed to Hamidreza Honarmand; honarmand.3@gmail.com

Received 24 May 2015; Revised 23 August 2015; Accepted 26 August 2015

Academic Editor: Ashrafus Safa

Copyright © 2015 Masoumeh Ahmadi Jalali Moghadam et al. This is an open access article distributed under the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

This study is designed to determine the contamination degree of hospital water supplies with *Pseudomonas aeruginosa*, *Legionella pneumophila*, and *E. coli* in Gilan, Iran. Samples were collected directly into sterile containers and concentrated by centrifuge. Half part of any sample transferred to yeast extract broth and the second part transferred to Trypticase Soy Broth and incubated for 3 days. DNA was extracted by using commercial kit. Four rounds of PCR were performed as follows: multiplex PCR for detecting *Pseudomonas aeruginosa*, Integron 1, and Metallo- β -lactamases gene; PCR for detecting *Legionella pneumophila* and *mip* gene separately; PCR for detecting *E. coli*; and another PCR for detecting whole bacterial presence. Contamination rates of cold, warm, and incubator water samples with *P. aeruginosa*, were 16.6%, 37.5%, and 6.8% consequently. Degrees of contamination with *L. pneumophila* were 3.3%, 9.3%, and 10.9% and with *E. coli* were zero, 6.2%, and zero. Total bacterial contamination of cold, warm, and incubator water samples was 93.3%, 84.4%, and 89.0% consequently. Metallo- β -lactamases gene was found in 20.0% of all samples. Contamination degree with *P. aeruginosa* was considerable and with *L. pneumophila* was moderate. Metallo- β -lactamases gene was found frequently indicating widespread multiple drug resistance bacteria. We suggest using new decontamination method based on nanotechnology.

1. Introduction

Nosocomial infection is an infection whose development is favored by a hospital environment. Microorganisms can be transmitted to the host by contaminated items, such as water. Water may be contaminated in many ways. The different forms of contamination come from different sources and are dealt with in different ways [1]. The three main forms of water contamination are physical, bacterial, and chemical [2]. Contamination can occur at the source, between source and storage points or in storage tanks. Defective joints, syphonage, rusted pipelines, and crossing over of sewage pipelines are other causes of contamination [3]. So, drinking water distribution systems may contain a diverse microbiological community that may include opportunistic pathogens

and it is the most important single source of human exposure to gastroenteric diseases, mainly as a result of the ingestion of microbial contaminated water [4].

Hospital outbreaks are usually associated with contamination of water sources [5]. Water contamination of respirators and incubators of newborns are the main sources of transfer [6, 7]. The cooling tower and the air condition system have also been reported to be sources of several outbreaks [8]. Man-made water systems especially hot water systems are main sources of *Legionella* [9]. These bacteria survive in biofilm and resist against chlorine and other disinfectants [9].

A wide variety of opportunistic pathogens such as *Pseudomonas* can be incorporated into the piped potable water, colonizing the surfaces of pipelines with high numbers of biofilm-forming bacteria [10]. In addition, in bacteriological

assessments, particularly for coliforms, the indicators of contamination by fecal matter must be routinely performed by many public health authorities to ascertain the quality of water to ensure prevention of further dissemination of pathogens through the agency of water [11].

Addition of chlorine in different water treatment plants is a common practice, but it is not sufficient to ensure the safety of water. There is adverse association between bacterial count of water samples and free residual chlorine but the failure of conventional treatment processes to eliminate critical waterborne pathogens in drinking water demands that improved and/or new disinfection technologies should be developed [4].

The aim of the present study was to determine the contamination rate of cold and warm water as well as water of containers of newborn incubators in hospitals of Gilan Province, Iran, by *Pseudomonas aeruginosa*, *Legionella pneumophila*, and *E. coli*, using molecular approach.

2. Materials and Methods

2.1. Sampling, Processing, and Enrichment. During April–June 2014, one hundred and thirty-five water samples (about 50 mL for each) were aseptically collected in 60 mL plastic containers from 30 hospitals of the area (30 cold water samples, 32 warm water samples, and 73 incubator water samples). Cold water and warm water samples were taken after the water had run for 5 min. Water samples of incubator of newborn wards were taken directly into sterile plastic containers. Potable water is supplied to the hospitals by the municipal system where it receives no additional treatment. The water has detectable free residual chlorine upon arrival at hospitals. All water samples were concentrated 20-fold (by dividing any sample into 5 falcon tubes, centrifugation with 12000 rpm for 30 min in 4°C, discarding supernatant, dissolving precipitant in 0.5 mL remaining water, and collecting them in a tube). After discarding supernatant, sediment was resolved in 1 mL of the remaining solution and was divided into two different parts. One part was treated in 50°C for 30 min to reduce other contaminants for effective recovering of *Legionella*. After heat treatment, each sample was inoculated in 5 mL liquid medium containing yeast extract 10 g/L, L-cysteine 0.04%, ferric pyrophosphate 0.25 g/L, glycine 0.3%, and vancomycin 5 µg/mL with final pH 6.9 and incubated in 35°C for 3 days. It should be noted that vancomycin and glycine are added to the medium after autoclave and when the temperature was around 40°C. The selectivity of the medium was subsequently improved by the incorporation of vancomycin and glycine. This selective medium should facilitate the recovery of Legionellaceae from environmental sources [9]. The second part of each sample was inoculated in Trypticase Soy Bean Broth and incubated in 35°C for 3 days for recovering *P. aeruginosa* and *E. coli*.

2.2. DNA Extraction and Primers. All cultured samples were divided over 1 mL in volume and centrifuged in a Sigma model 3k30 centrifuge at 12,000 rpm in 4°C for 20 min. The supernatant was discarded, and the pellet was suspended with 1 mL of TE buffer before DNA extraction. DNA was extracted

by using commercial procedure (Genomic DNA Purification Kit, Thermo Scientific, Lot: 00155557, Fermentas, Lithuania). The extracted DNA was either used immediately for PCR or stored at –20°C until analysis.

Several rounds of PCR were performed to detect *P. aeruginosa*, Integron 1, Metallo-β-lactamases gene, *Legionella pneumophila*, *mip* gene, and *E. coli* as the following procedure: (1) conventional PCR by using specific primers for *L. pneumophila* and *mip* gene separately, (2) multiplex PCR by using specific primers for *P. aeruginosa*, Integron 1, and Metallo-β-lactamases gene, (3) conventional PCR for detecting *E. coli* using specific primers, and (4) final round of PCR to investigate total presence of bacteria by using universal primers. Primers which were used in this study are characterised in Table 1.

We used genomic DNA of *L. pneumophila* type strain NCTC 11192 as positive control for the first round of PCR. A standard strain of *P. aeruginosa* (ATCC 27853) was used as positive control for the second round of PCR, and *E. coli* (ATCC 44338) was used as positive control for third and fourth rounds of PCR. Pure water was used as negative control for all rounds of PCR.

2.3. PCR Conditions. Two microliters of the extracted template DNA was used in a 20 µL reaction mixture that included 10 µL of PCR premix [Prime Taq Premix (2x), Chorea Lot number 201208], 0.5 µL of each primer, and 7 µL of ddH₂O. Cycling program for first round amplification of *L. pneumophila* (species specific fragment) was as follows: an initial denaturation at 94°C for 5 min and then 35 cycles consisting of 94°C for 60 s, 45°C for 50 s, and 72°C for 60 s were followed by a final extension at 72°C for 10 min. Cycling program for second round of PCR was the same but the annealing temperature was 50°C. Annealing temperature for third round of PCR was 58°C and for 16S rRNA amplification with the universal primers was 47°C with the same cycling program. Electrophoresis of amplified product was performed on agarose gel (2% w/v) by 125 volts for 45 minutes and analyzed by GelDocTransluminator system (VilberLourmat model).

3. Results

One hundred and thirty-five water samples were aseptically collected from 30 hospitals of the area (30 cold water, 32 warm water, and 73 incubator water samples). Contamination rates of cold, warm, and incubator water samples with *P. aeruginosa* were 16.6%, 37.5%, and 6.8% consequently (Tables 2–4 and Figure 1). Degrees of contamination with *L. pneumophila* were 3.3%, 9.3%, and 10.9% (Tables 2–4 and Figure 2) and with *E. coli* were zero, 6.2%, and zero (Tables 2–4 and Figure 3). Total bacterial contamination of cold, warm, and incubator water samples was 93.3%, 84.4%, and 89.0% consequently (Tables 2–4 and Figure 4).

Metallo-β-lactamases gene was found in 20.0% of cold water samples, 15.6% of warm water samples, and 21.9% of incubator water samples (Tables 2–4). About 60.0% of *P. aeruginosa* in incubator samples had Metallo-β-lactamases

TABLE 1: Characteristic of primers used in the present study.

Primer	Sequence (5' → 3')	Use	Reference
Lpms1F Lpms1R	CAGGGAAATGCTCTAGCACAC TCGCTTCGGACTGAATTTCT	<i>L. pneumophila</i> detection	[12]
Lmip F Lmip R	GGCCAATAGGTCCGCCAACG GGTGACTGCGGCTGTTATGG	<i>mip</i> gene detection	[13]
gyrB-F gyrB-R	CCTGACCATCCGTGCCACAAC CGCAGCAGGATGCCGACGCC	<i>P. aeruginosa</i> detection	[14]
Vim1-1A Vim1-1B	TTATGGAGCAGCAACGATGT CAAAAGTCCCCGCTCCAACGA	blaVIM detection	[15]
Int1-1A Int1-1B	TACCTCTCACTAGTGAGGGG ATGAAAACCGCCACTGCGCC	int1 detection	[16]
EPE-F EPE-R	CCCGAATTCGGCACAAGCATAAGC CCCGGATCCGTCTCGCCAGTATTCG	<i>E. coli</i> detection	[17]
16srRNA F 16srRNA R	GGATTAGATACCCTGGTAGTCC TCGTTGCGGGACTTAACCCAAC	Detection of whole bacterial load	[18]

TABLE 2: Summary of amplification results for cold water samples.

<i>P. aeruginosa</i>	Metallo- β -lactamases gene	Integron I	Coliform	<i>L. pneumophila</i>	<i>mip</i> gene	Total bacterial contamination rate
5 (30)	6 (30)	0	0	1 (30)	0	28 (30)
16.6%	20.0%	0	0	3.3%	0	93.3%

gene, 42.0% of warm water samples had *P. aeruginosa* with this gene, and 10.0% of *P. aeruginosa* in cold water samples had the same gene.

About 8.3% of *P. aeruginosa* in warm water samples had Integron 1 but we did not find *P. aeruginosa* with Integron 1 in any sample of incubators and cold water. We also did not find *P. aeruginosa* with both Integron 1 and Metallo- β -lactamases gene in incubator and cold water samples and just 1 of 12 *P. aeruginosa* of warm water sample had both Integron 1 and Metallo- β -lactamases gene.

About 25.0% of *L. pneumophila* in incubator samples had *mip* gene and 33.3% of warm water samples had *L. pneumophila* with *mip* gene. We did not find *L. pneumophila* with *mip* gene in cold water samples.

In total, 88.9% of all samples showed bacterial contamination as revealed by PCR with universal primers, 16.3% of all samples had *P. aeruginosa*, 8.9% had *L. pneumophila*, and 1.5% had *E. coli*. The Metallo- β -lactamases gene was found in 20.0% and Integron 1 was found in 3.0% of all samples.

4. Discussion

The ability of microbes to survive in hospital water reservoir was described more than 30 years ago, and numerous studies have confirmed hospital water as a source of nosocomial infection [19]. The bacterial contamination level related to the tap water was a point of dispersion of bacterial species, including potentially pathogenic organisms [20]. Modes of transmission for waterborne infections include direct contact, ingestion of water, indirect contact, inhalation of aerosols dispersed from water sources, and aspiration of contaminated water [21].

Several factors could be attributed to the contamination of surface water such as the age of the distribution system,




FIGURE 1: Results of multiplex PCR with primers specific for *P. aeruginosa* species, Integron 1, and Metallo- β -lactamases gene, for 13 incubator samples. Line 16 is 100–1000 bp ladder. Line 15 is positive control (*P. aeruginosa* type strain ATCC 27853). Lines 5 and 12 are positive samples for *P. aeruginosa* (720 bp specific bands). Lines 2, 5, 8, and 10 are positive samples for Metallo- β -lactamases gene (310 bp). All samples are negative for Integron 1. Lines 3, 4, 6, 7, 11, 13, and 14 are negative samples and line 1 is negative control (water).

the quality of the delivered water, defective chlorination, and improper maintenance [22]. Contamination can occur at the source, between source and storage points or in storage tanks [3]. The bacterial contamination occurs because of regrowth of microorganisms in biofilms which are formed on interior surfaces of water pipes. Biological activity in biofilms is controlled by nutrient content of water, temperature, and residual chlorine [23].

Microorganisms are widely distributed in nature and their abundance and diversity may be used as indicators for suitability of water [24]. Certain types of microorganisms are characteristics of human fecal contamination [25]. In the present study we used three bacteria (*E. coli*, *P. aeruginosa*,

TABLE 3: Summary of amplification results for warm water samples.

<i>P. aeruginosa</i>	Metallo- β -lactamases gene	Integron I	Coliform	<i>L. pneumophila</i>	<i>mip</i> gene	Total bacterial contamination rate
12 (32)	5 (32)	1 (32)	2 (32)	3 (32)	1 (32)	27 (32)
37.5%	15.6%	3.1%	6.2%	9.3%	3.1%	84.4%

TABLE 4: Summary of amplification results for incubators water samples.

<i>P. aeruginosa</i>	Metallo- β -lactamases gene	Integron I	Coliform	<i>L. pneumophila</i>	<i>mip</i> gene	Total bacterial contamination rate
5 (73)	16 (73)	3 (73)	0	8 (73)	2 (73)	65 (73)
6.8%	21.9%	4.1%	0	10.9%	2.7%	89.0%




FIGURE 2: Results of PCR with *L. pneumophila*: species specific primers for 13 incubator samples. Line 1 is positive control (*L. pneumophila* type strain NCTC 11192). Lines 2 and 7 are ladders (100–1000 bp). Lines 3, 4, 5, 6, 8, 10, and 11 are positive samples. Lines 9, 12, 13, 14, and 15 are negative samples and line 16 is negative control (water).




FIGURE 4: Results of PCR with universal primer for bacterial 16S rRNA gene for 13 incubator samples. Line 2 is positive control (*E. coli* type strain ATCC 44338). Lines 1 and 9 are ladders (100–1000 bp). Lines 3, 4, 5, 8, 10, 11, 12, 13, 14, and 15 are positive samples. Lines 6, 7, and 13 are negative samples, and line 16 is negative control (water).




FIGURE 3: Results of PCR with *E. coli* species specific primers for 13 incubator samples. Line 16 is 100–1000 bp ladder. Line 15 is negative control (water). Line 14 is positive control (*E. coli* type strain ATCC 44338). All samples (lines 1–13) are negative.

and *L. pneumophila*) to evaluate quality of studied water supplies because river and underground waters are main sources of tap water in the area and these bacteria are main human pathogens with water sources. Actually in this study, *E. coli* was used as a representative of the enteric bacterial pathogens. We also used *L. pneumophila* as ubiquitous waterborne microorganism and *P. aeruginosa* as ubiquitous waterborne opportunistic pathogen.

E. coli is a type of fecal coliform bacteria commonly found in the intestines of animals and humans and the presence of it in water is a strong indication of recent sewage or animal waste contamination [26]. We did not find *E. coli* in cold water and incubator water samples and just two warm water samples showed presence of *E. coli*. In some similar studies water distribution systems of examined hospitals were totally free of Gram-negative bacteria belonging to family Enterobacteriaceae [27]. Although coliforms are known as the best index for monitoring water microbial quality, in some cases this index is not very efficient. Some believe that the excess growth of heterotrophic bacteria results in suppression of the coliforms. Therefore, it is recommended to use other bacteria as an alternative index in water microbial quality control and *Pseudomonas* can be one of these indicators [28].

P. aeruginosa is part of a large group of free-living bacteria that are ubiquitous in the environment. *P. aeruginosa* is of major concern in hospitals, since it can cause severe secondary infections, such as pneumonia in burn victims or immunocompromised persons [29]. Its occurrence in drinking water is probably related more to its ability to colonize biofilms in plumbing fixtures (i.e., faucets and showerheads) than its presence in the distribution system or treated drinking water. *P. aeruginosa* can survive in deionized or distilled water; hence, it may be found in low nutrient or oligotrophic environments such as distilled water which

is used for incubators of newborn ward [30]. In the present study contamination degree of warm water with *P. aeruginosa* was higher (37.5%) than cold water (16.6%) and incubator water (6.8%). High temperatures of water can be favorable for the growth of *P. aeruginosa* [30]. It also can be isolated even in the presence of 3.00 ppm residual free chlorine [30].

A number of laboratory-based studies have demonstrated the colonization of heterogeneous biofilms developed from tap water microorganisms by pathogens such as *E. coli* [31], *L. pneumophila* [32], and *P. aeruginosa* [33]. A number of studies showed that these bacteria are important opportunistic pathogens which can be involved in biofilm-associated contamination of domestic plumbing systems [34–37].

De Abreu et al. presented that biofilm tap water was the major environmental source of pseudomonads in the health-care facility [20]. In the present study the frequency of *P. aeruginosa* with Metallo- β -lactamases was 37%. It should be noted that Metallo- β -lactamases producing strains have been increasingly reported worldwide and have been responsible for large outbreaks in several Asian, European, and American hospitals [38–42]. Genes encoding Metallo- β -lactamases are generally located within class 1 integrons, together with those encoding aminoglycoside-modifying enzymes that confer multidrug resistance. In addition, the integrons harboring Metallo- β -lactamases determinants are frequently located on plasmids, certainly facilitating their intra- and interspecies spread [43]. High prevalence of Metallo- β -lactamases producing epidemic or endemic strains is also found in other Mediterranean countries, such as Italy and Greece [44].

Presence of *L. pneumophila* is associated with biofilms in warm water plumbing systems [45]. This bacterium can also survive at lower temperatures in drinking water environments [46, 47]. *L. pneumophila*, particularly strains within serogroups 1 and 6, is known as cause of both community acquired and hospital associated pneumonia [48, 49]. Transmission to humans occurs through inhalation of aerosols generated from an environmental source. Several reports have demonstrated that the major sources for Legionnaires' disease are the potable water systems of large buildings including hospitals, nursing home, and hotels [50].

In a similar study, Yaslianifard et al. found considerable contamination rate of *L. pneumophila* and *P. aeruginosa* in hospital water samples in Tehran, Iran [51]. Shamabadi and Ebrahimi found low rate contamination with Gram-negative flora, moderate concentrations of *Legionella*, and potentially pathogenic nonenterobacterial species [28].

In the present study we found the degree of presence of *L. pneumophila* in cold water was lower than in warm water and incubator water. It seems that high loads of *P. aeruginosa* can mask the presence of *Legionella*, leading to an underestimation in some cases. Many authors agree that different microbe species as well as high microbial loads can play an important role in limiting or even inhibiting the growth of *Legionella* [52, 53]. In our study the total bacterial contamination of cold water samples was very high (93.3%). Actually overall pollution of hospital water systems with *Legionella* found in the present work was smaller compared to earlier studies made in Germany and Italy [54–57]. In a USA national surveillance study of 20 hospitals in 13 states, 14

hospitals were colonized with *Legionella* in the water systems in which 43% of hospitals had environmental positive rates for *Legionella* [58]. In a study in Spain on 12 hospitals, the environmental positive rates for *Legionella* were $\geq 30\%$ [59]. *L. pneumophila* was also found in 63% of hospital water systems in Taiwan [52].

The present study showed that care should be taken concerning cleanliness and decontamination of water supplies for pathogenic organisms. Chlorine has been widely used as disinfectant due to its low cost and effectiveness in many countries but it is not sufficient to ensure the safety of water. The maintenance of chlorine residue is needed at all points in distribution system supplied with chlorine as a disinfectant [60]. The failure of conventional treatment processes to eliminate critical waterborne pathogens in drinking water demands that improved and/or new disinfection technologies be developed. Recent research has disclosed that nanotechnology may offer solutions in this area, through the use of nanosorbents, nanocatalysts, bioactive nanoparticles, nanostructured catalytic membranes, and nanoparticle-enhanced filtration [4].

5. Conclusion

Our study demonstrated that contamination degree of studied water samples with *P. aeruginosa* was considerable, with *L. pneumophila* was moderate, and with *E. coli* was very low. We also found frequent presence of Metallo- β -lactamases gene in the studied water samples indicating widespread multiple drug resistance bacteria. We suggest using new decontamination method based on new disinfection technologies.

Conflict of Interests

The authors declare that there is no conflict of interests regarding the publication of this paper.

Acknowledgment

This work is financially supported by Guilan University of Medical Sciences.

References

- [1] C. Fall, A. Hinojosa-Peña, and M. C. Carreño-de-León, "Design of a monitoring network and assessment of the pollution on the Lerma river and its tributaries by wastewaters disposal," *Science of the Total Environment*, vol. 373, no. 1, pp. 208–219, 2007.
- [2] S. Mor, K. Ravindra, R. P. Dahiya, and A. Chandra, "Leachate characterization and assessment of groundwater pollution near municipal solid waste landfill site," *Environmental Monitoring and Assessment*, vol. 118, no. 1–3, pp. 435–456, 2006.
- [3] R. Feachem, "Bacterial standards for drinking water quality in developing countries," *The Lancet*, vol. 2, no. 8188, pp. 255–256, 1980.
- [4] N. Ngwenya, E. J. Ncube, and J. Parsons, "Recent advances in drinking water disinfection: successes and challenges," *Reviews of Environmental Contamination and Toxicology*, vol. 222, pp. 111–170, 2013.

- [5] P. S. Graman, G. A. Quinlan, and J. A. Rank, "Nosocomial legionellosis traced to a contaminated ice machine," *Infection Control and Hospital Epidemiology*, vol. 18, no. 9, pp. 637–640, 1997.
- [6] L. Franzin, C. Scolfaro, D. Cabodi, M. Valera, and P. A. Tovo, "*Legionella pneumophila* pneumonia in a newborn after water birth: a new mode of transmission," *Clinical Infectious Diseases*, vol. 33, no. 9, pp. e103–e104, 2001.
- [7] R. E. Holmberg Jr., A. T. Pavia, D. Montgomery, J. M. Clark, and L. D. Eggert, "Nosocomial *Legionella pneumonia* in the neonate," *Pediatrics*, vol. 92, no. 3, pp. 450–453, 1993.
- [8] P. Delgado-Viscogliosi, T. Simonart, V. Parent et al., "Rapid method for enumeration of viable *Legionella pneumophila* and other *Legionellasp.* in water," *Applied and Environmental Microbiology*, vol. 71, no. 7, pp. 4086–4096, 2005.
- [9] P. Borella, M. T. Montagna, S. Stampi et al., "*Legionella* contamination in hot water of Italian hotels," *Applied and Environmental Microbiology*, vol. 71, no. 10, pp. 5805–5813, 2005.
- [10] F. Codony, J. Morató, and J. Mas, "Role of discontinuous chlorination on microbial production by drinking water biofilms," *Water Research*, vol. 39, no. 9, pp. 1896–1906, 2005.
- [11] B. R. Swistock and W. E. Sharpe, "The influence of well construction on bacterial contamination of private water wells in Pennsylvania," *Journal of Environmental Health*, vol. 68, no. 2, pp. 17–22, 2005.
- [12] C. Pourcel, Y. Vidgop, F. Ramisse, G. Vergnaud, and C. Tram, "Characterization of a tandem repeat polymorphism in *Legionella pneumophila* and its use for genotyping," *Journal of Clinical Microbiology*, vol. 41, no. 5, pp. 1819–1826, 2003.
- [13] D. S. J. Lindsay, W. H. Abraham, and R. J. Fallon, "Detection of *mip* gene by PCR for diagnosis of Legionnaires' disease," *Journal of Clinical Microbiology*, vol. 32, no. 12, pp. 3068–3069, 1994.
- [14] R. Lavenir, D. Jocktane, F. Laurent, S. Nazaret, and B. Cournoyer, "Improved reliability of *Pseudomonas aeruginosa* PCR detection by the use of the species-specific *ecfX* gene target," *Journal of Microbiological Methods*, vol. 70, no. 1, pp. 20–29, 2007.
- [15] J.-J. Yan, P.-R. Hsueh, W.-C. Ko et al., "Metallo- β -lactamases in clinical *Pseudomonas* isolates in Taiwan and identification of VIM-3, a novel variant of the VIM-2 enzyme," *Antimicrobial Agents and Chemotherapy*, vol. 45, no. 8, pp. 2224–2228, 2001.
- [16] J.-J. Yan, P.-R. Hsueh, J.-J. Lu, F.-Y. Chang, W.-C. Ko, and J.-J. Wu, "Characterization of acquired β -lactamases and their genetic support in multidrug-resistant *Pseudomonas aeruginosa* isolates in Taiwan: the prevalence of unusual integrons," *Journal of Antimicrobial Chemotherapy*, vol. 58, no. 3, pp. 530–536, 2006.
- [17] E. Oswald, H. Schmidt, S. Morabito, H. Karch, O. Marchès, and A. Caprioli, "Typing of intimin genes in human and animal enterohemorrhagic and enteropathogenic *Escherichia coli*: characterization of a new intimin variant," *Infection and Immunity*, vol. 68, no. 1, pp. 64–71, 2000.
- [18] R. Kariyama, R. Mitsuhashi, J. W. Chow, D. B. Clewell, and H. Kumon, "Simple and reliable multiplex PCR assay for surveillance isolates of vancomycin-resistant enterococci," *Journal of Clinical Microbiology*, vol. 38, no. 8, pp. 3092–3095, 2000.
- [19] E. J. Anaissie, S. R. Penzak, and M. C. Dignani, "The hospital water supply as a source of nosocomial infections: a plea for action," *Archives of Internal Medicine*, vol. 162, no. 13, pp. 1483–1492, 2002.
- [20] P. M. De Abreu, P. G. Farias, G. S. Paiva, A. M. Almeida, and P. V. Morais, "Persistence of microbial communities including *Pseudomonas aeruginosa* in a hospital environment: A potential health hazard," *BMC Microbiology*, vol. 14, article 118, 2014.
- [21] L. Sehulster and R. Chinn, *Guidelines for Environmental Infection Control in Health-Care Facilities*, Center for Disease Control (CDC), 2003, <http://www.cdc.gov/ncidod/hip/enviro/guide.htm>.
- [22] R. Radha Krishnan, K. Dharmaraj, and B. D. R. Kumari, "A comparative study on the physicochemical and bacterial analysis of drinking, borewell and sewage water in the three different places of Sivakasi," *Journal of Environmental Biology*, vol. 28, no. 1, pp. 105–108, 2007.
- [23] D. Gatel, P. Servais, J. C. Block, P. Bonne, and J. Cavard, "Microbiological water quality management in the Paris suburbs distribution system," *Journal of Water Supply: Research and Technology*, vol. 49, pp. 231–241, 2000.
- [24] D. A. Popko, S.-K. Han, B. Lanoil, and W. E. Walton, "Molecular ecological analysis of planktonic bacterial communities in constructed wetlands invaded by *Culex* (Diptera: Culicidae) mosquitoes," *Journal of Medical Entomology*, vol. 43, no. 6, pp. 1153–1163, 2006.
- [25] M. M. Yassin, S. S. A. Amr, and H. M. Al-Najar, "Assessment of microbiological water quality and its relation to human health in Gaza Governorate, Gaza Strip," *Public Health*, vol. 120, no. 12, pp. 1177–1187, 2006.
- [26] J. B. Alam, A. Hossain, S. K. Khan et al., "Deterioration of water quality of Surma river," *Environmental Monitoring and Assessment*, vol. 134, no. 1–3, pp. 233–242, 2007.
- [27] N. M. Stojek, J. Szymańska, and J. Dutkiewicz, "Gram-negative bacteria in water distribution systems of hospitals," *Annals of Agricultural and Environmental Medicine*, vol. 15, no. 1, pp. 135–142, 2008.
- [28] N. Shamabadi and M. Ebrahimi, "Use of bacterial indicators for contamination in drinking water of Qom, Iran," *Journal of Applied Sciences*, vol. 7, no. 17, pp. 2456–2461, 2007.
- [29] M. S. Inslar and H. Gore, "Pseudomonas keratitis and folliculitis from whirlpool exposure," *American Journal of Ophthalmology*, vol. 101, no. 1, pp. 41–43, 1986.
- [30] K. D. Mena and C. P. Gerba, "Risk assessment of *Pseudomonas aeruginosa* in water," *Reviews of Environmental Contamination and Toxicology*, vol. 201, pp. 71–115, 2009.
- [31] C. M. Buswell, H. S. Nicholl, and J. T. Walker, "Use of continuous culture bioreactors for the study of pathogens such as *Campylobacter jejuni* and *Escherichia coli* O 157 in biofilms," *Methods in Enzymology*, vol. 337, pp. 70–78, 2001.
- [32] R. Murga, T. S. Forster, E. Brown, J. M. Pruckler, B. S. Fields, and R. M. Donlan, "Role of biofilms in the survival of *Legionella pneumophila* in a model potable-water system," *Microbiology*, vol. 147, no. 11, pp. 3121–3126, 2001.
- [33] M. M. Moritz, H.-C. Flemming, and J. Wingender, "Integration of *Pseudomonas aeruginosa* and *Legionella pneumophila* in drinking water biofilms grown on domestic plumbing materials," *International Journal of Hygiene and Environmental Health*, vol. 213, no. 3, pp. 190–197, 2010.
- [34] K. E. Eboigbodin, A. Seth, and C. A. Biggs, "A review of biofilms in domestic plumbing," *Journal—American Water Works Association*, vol. 100, no. 10, pp. 12–138, 2008.
- [35] F. Emtiazi, T. Schwartz, S. M. Marten, P. Krolla-Sidenstein, and U. Obst, "Investigation of natural biofilms formed during the production of drinking water from surface water embankment filtration," *Water Research*, vol. 38, no. 5, pp. 1197–1206, 2004.

- [36] B. Kilb, B. Lange, G. Schaule, H.-C. Flemming, and J. Wiegand, "Contamination of drinking water by coliforms from biofilms grown on rubber-coated valves," *International Journal of Hygiene and Environmental Health*, vol. 206, no. 6, pp. 563–573, 2003.
- [37] D.-G. Lee and S.-J. Kim, "Bacterial species in biofilm cultivated from the end of the Seoul water distribution system," *Journal of Applied Microbiology*, vol. 95, no. 2, pp. 317–324, 2003.
- [38] C. Lagatolla, E. Edalucci, L. Dolzani et al., "Molecular evolution of metallo- β -lactamase-producing *Pseudomonas aeruginosa* in a nosocomial setting of high-level endemicity," *Journal of Clinical Microbiology*, vol. 44, no. 7, pp. 2348–2353, 2006.
- [39] K. B. Laupland, M. D. Parkins, D. L. Church et al., "Population-based epidemiological study of infections caused by carbapenem-resistant *Pseudomonas aeruginosa* in the Calgary Health Region: importance of metallo- β -lactamase (MBL)-producing strains," *Journal of Infectious Diseases*, vol. 192, no. 9, pp. 1606–1612, 2005.
- [40] K. Lolans, A. M. Queenan, K. Bush, A. Sahud, and J. P. Quinn, "First nosocomial outbreak of *Pseudomonas aeruginosa* producing an integron-borne metallo- β -lactamase (VIM-2) in the United States," *Antimicrobial Agents and Chemotherapy*, vol. 49, no. 8, pp. 3538–3540, 2005.
- [41] L. Pagani, C. Colinson, R. Migliavacca et al., "Nosocomial outbreak caused by multidrug-resistant *Pseudomonas aeruginosa* producing IMP-13 metallo- β -lactamase," *Journal of Clinical Microbiology*, vol. 43, no. 8, pp. 3824–3828, 2005.
- [42] K. Senda, Y. Arakawa, K. Nakashima et al., "Multifocal outbreaks of metallo-beta-lactamase-producing *Pseudomonas aeruginosa* resistant to broad-spectrum beta-lactams, including carbapenems," *Antimicrobial Agents and Chemotherapy*, vol. 40, no. 2, pp. 349–353, 1996.
- [43] A. Y. Peleg, C. Franklin, J. M. Bell, and D. W. Spelman, "Dissemination of the metallo- β -lactamase gene blaIMP-4 among gram-negative pathogens in a clinical setting in Australia," *Clinical Infectious Diseases*, vol. 41, no. 11, pp. 1549–1556, 2005.
- [44] S. Pournaras, M. Maniati, E. Petinaki et al., "Hospital outbreak of multiple clones of *Pseudomonas aeruginosa* carrying the unrelated metallo- β -lactamase gene variants blaVIM-2 and blaVIM-4," *Journal of Antimicrobial Chemotherapy*, vol. 51, no. 6, pp. 1409–1414, 2003.
- [45] H. Y. Lau and N. J. Ashbolt, "The role of biofilms and protozoa in *Legionella* pathogenesis: implications for drinking water," *Journal of Applied Microbiology*, vol. 107, no. 2, pp. 368–378, 2009.
- [46] M. S. Gião, S. A. Wilks, N. F. Azevedo, M. J. Vieira, and C. W. Keevil, "Comparison between standard culture and peptide nucleic acid 16S rRNA hybridization quantification to study the influence of physico-chemical parameters on *Legionella pneumophila* survival in drinking water biofilms," *Biofouling*, vol. 25, no. 4, pp. 343–351, 2009.
- [47] M. J. Lehtola, E. Torvinen, J. Kusnetsov et al., "Survival of *Mycobacterium avium*, *Legionella pneumophila*, *Escherichia coli*, and caliciviruses in drinking water-associated biofilms grown under high-shear turbulent flow," *Applied and Environmental Microbiology*, vol. 73, no. 9, pp. 2854–2859, 2007.
- [48] B. M. W. Diederer, "Legionella spp. and Legionnaires' disease," *Journal of Infection*, vol. 56, no. 1, pp. 1–12, 2008.
- [49] G. W. Waterer, V. S. Baselski, and R. G. Wunderink, "Legionella and community-acquired pneumonia: a review of current diagnostic tests from a clinician's viewpoint," *American Journal of Medicine*, vol. 110, no. 1, pp. 41–48, 2001.
- [50] P.-Y. Yu, Y. E. Lin, W.-R. Lin et al., "The high prevalence of *Legionella pneumophila* contamination in hospital potable water systems in Taiwan: implications for hospital infection control in Asia," *International Journal of Infectious Diseases*, vol. 12, no. 4, pp. 416–420, 2008.
- [51] S. Yaslianifard, B. M. Fatolahzadeh, M. Feizabadi, and A. M. Mobarez, "Colonization of hospital water systems by *Legionella pneumophila*, *Pseudomonas aeruginosa*, and *Acinetobacter* in ICU wards of Tehran hospitals," *Indian Journal of Pathology and Microbiology*, vol. 55, no. 3, pp. 352–356, 2012.
- [52] L. Veronesi, E. Capobianco, P. Affanni, S. Pizzi, P. Vitali, and M. L. Tanzi, "Legionella contamination in the water system of hospital dental settings," *Acta Bio-Medica*, vol. 78, no. 2, pp. 117–122, 2007.
- [53] L. G. Cordes, A. M. Wiesenthal, G. W. Gorman et al., "Isolation of *Legionella pneumophila* from hospital shower heads," *Annals of Internal Medicine*, vol. 94, no. 2, pp. 195–197, 1981.
- [54] K. Botzenhart, W. Heizmann, S. Sedaghat, P. Heeg, and T. Hahn, "Bacterial colonization and occurrence of *Legionella pneumophila* in warm and cold water, in faucet aerators, and in drains of hospitals," *Zentralblatt für Bakteriologie, Mikrobiologie und Hygiene*, vol. 183, no. 1, pp. 79–85, 1986.
- [55] U. Kalker and W. Hentschel, "Legionella contamination in warm water systems of a large German city," *Gesundheitswesen*, vol. 54, no. 10, pp. 597–604, 1992.
- [56] P. P. Legnani, E. Leoni, and N. Corradini, "Legionella contamination of hospital water supplies: monitoring of private health-care facilities in Bologna, Italy," *Journal of Hospital Infection*, vol. 50, no. 3, pp. 220–223, 2002.
- [57] P. C. Lück, I. Leupold, M. Hlawitschka et al., "Prevalence of Legionella species, serogroups, and monoclonal subgroups in hot water systems in south-eastern Germany," *Zentralblatt für Hygiene und Umweltmedizin*, vol. 193, no. 5, pp. 450–460, 1993.
- [58] J. E. Stout, R. R. Muder, S. Mietzner et al., "Role of environmental surveillance in determining the risk of hospital-acquired legionellosis: a national surveillance study with clinical correlations," *Infection Control and Hospital Epidemiology*, vol. 28, no. 7, pp. 818–824, 2007.
- [59] M. Sabrià, J. M. Mòdol, M. Garcia-Núñez et al., "Environmental cultures and hospital-acquired legionnaires' disease: a 5-year prospective study in 20 hospitals in Catalonia, Spain," *Infection Control and Hospital Epidemiology*, vol. 25, no. 12, pp. 1072–1076, 2004.
- [60] G. R. Munavalli and M. S. Mohan Kumar, "Water quality parameter estimation in steady-state distribution system," *Journal of Water Resources Planning and Management*, vol. 129, no. 2, pp. 124–134, 2003.